			TDSR A	TDSR B	TDSR C	Will	Will Rogers	Project	Act	Station Data Summary
			A		C	Rogers Dust 1	Dust 2	Target	ion Lev el	
	PM 2.5	Avg, ug/M3	19	12	12			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
3/16/2025	PM 10		42	18	19			300	150	10.00.00
	PM 2.5	Avg, ug/M	18	13	13			70	35	TDSR-A had multiple operational alerts as a result of being directly downwind of the concrete cutting operations at the TDSR, adding to the already elevated levels of ambient PM 2.5 for the day. The
3/17/2025	PM 10	Avg, ug/M	43	22	19			300	150	AMT asked the crew to increase water usage. There were 0 exceedances of the Action Level or Project Target level for the day.
3/18/2025	PM 2.5	Avg, ug/M3	13	9	8			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
	PM 10		31	14	13			300	150	lever for the day.
3/19/2025	PM 2.5	Avg, ug/M3	11	8	9			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
	PM 10	Avg, ug/M3	27	12	16			300	150	
3/20/2025	PM 2.5	Avg, ug/M3	13	8	9			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
	PM 10	Avg, ug/M3	33	12	17			300	150	
3/21/2025	PM 2.5	Avg, ug/M3 Avg,	14	10	10			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
	PM 10	ug/M3	33	20	18			300	150	
3/22/2025	PM 2.5	Avg, ug/M 3	16		15			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
3,22,2023	PM 10	Avg, ug/M 3	36		23			300	150	
3/23/2025	PM 2.5	Avg, ug/M 3	19					70	35	TDSR B and TDSR C did not transmit data. There were 0 exceedances of the Project Target level for the day.
5/25/2025	PM 10	Avg, ug/M 3	43					300	150	
	PM 2.5	Avg, ug/M 3	15					70	35	TDSR B and TDSR C did not transmit data. There were 0 exceedances of the Project Target level for the day.
3/24/2025	PM 10	Avg,	37					300	150	
3/25/2025	PM 2.5	Avg, ug/M 3	12	13	12			70	35	The ambient PM2.5 levels ranged from 14.6 to 36 ug/m^3 throughout the day.
	PM 10		28	18	14			300	150	There were 0 exceedances of the Project Target level for the day.
	PM 2.5	Avg, ug/M3	4	3	3			70	35	There were 0 exceedances of the Action Level or the Project Target level for the day.
3/26/2025	PM 10		12	4	6			300	150	Table 1.5. To the day.
3/27/2025	PM 2.5	Avg, ug/M3	6	5	3			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
	PM 10	-	16	8	7			300	150	
2/26/27	PM 2.5	Avg, ug/M3	14	12	12			70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
3/28/2025	PM 10	Avg, ug/M3	34	19	20			300	150	·

3/29/2025	PM	Avg,	12	14	11	 	70	35	There were 0 exceedances of the Action Level or Project Target
	2.5 PM 10	-	31	22	18	 	300	150	level for the day.
3/30/2025	PM 2.5	ug/M3 Avg, ug/M3	6	8	5	 	70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
	PM 10		21	11	8	 	300	150	level for the day.
	PM 2.5	Avg, ug/M3	8	8	7	 	70	35	There were 0 exceedances of the Action Level or Project Target level for the day.
3/31/2025	PM 10	٥,	19	12	8	 	300	150	·
	PM 2.5	3 Avg, ug/M 3	9	9	9	 	70	35	There were 0 exceedances of the Action Level or Project Limit level for the day.
4/1/2025	PM 10		28	12	16	 	300	150	
4/2/2025	PM 2.5	Avg, ug/M3	12	9	11	 	70	35	There were 0 exceedances of the Action Level or Project Limit level for the day.
4/2/2025	PM 10	Avg, ug/M3	23	11	18	 	300	150	
4/3/2025	PM 2.5	Avg, ug/M3	12	10	10	 	70	35	There were 0 exceedances of the Action Level or Project Limit level for the day.
4/3/2023	PM 10	Avg, ug/M3	25	12	15	 	300	150	
4/4/2025	PM 2.5	Avg, ug/M 3	9	10	8	 	70	35	There were 0 exceedances of the Action Level or Project Limit level for the day.
+) +) 2023	PM 10	Avg, ug/M 3	28	12	13	 	300	150	
4/E/202E	PM 2.5	Avg, ug/M 3	42	11	14	 	70	35	There were 0 exceedances of the Project Limit level for the day. TDSR A exceeded the PM 2.5 Action
4/5/2025	PM 10	Avg, ug/M 3	22	8	18	 	300	150	
4/C/2025	PM 2.5	Avg, ug/M 3	15	9	10	 	70	35	There were 0 exceedances of the Project Limit level for the day.
4/6/2025	PM 10	Avg, ug/M 3	31	10	15	 	300	150	
4/7/2025	PM 2.5	Avg, ug/M 3	9	11	11	 	70	35	There were 0 exceedances of the Project Limit for the day.
	PM 10	Avg, ug/M3	33	13	17	 	300	150	
4/8/2025	PM 2.5	Avg, ug/M3	17	11	12	 	70	35	There were 0 exceedances of the Project Limit for the day.
	PM 10	Avg, ug/M3	40	16	20	 	300	150	
4/9/2025	PM 2.5	Avg, ug/M3	25	16	20	 	70	35	There were 0 exceedances of the Project Limit for the day.
	PM 10	Avg, ug/M3	49	24	30	 	300	150	
4/10/2025	PM 2.5	Avg, ug/M3	15	10	11	 	70	35	There were 0 exceedances of the Action level or Project Limit for the day.
	PM 10	ug/M3	28	14	17	 	300	150	
4/11/2025	PM 2.5	Avg, ug/M3	17	13	13	 	70	35	There were 0 exceedances of the Action level or Project Limit for the day.
	PM 10	Avg, ug/M3	34	20	18	 	300	150	
4/12/2025	PM 2.5	Avg, ug/M3	45	40	43	 	70	35	There were 0 exceedances of the Project Limit for the day.

	PM 10	Avg, ug/M3	77	58	47			300	150	
	PM 2.5	Avg, ug/M3	32	30	27			70	35	There were 0 exceedances of the Project Limit for the day.
4/13/2025	PM 10	Avg, ug/M 3	60	44	31			300	150	
4/14/2025	PM 2.5	Avg, ug/M3	18	20	14			70	35	There were 0 exceedances of the Action level or Project Limit for the day.
4/14/2025	PM 10	Avg, ug/M3	34	28	19			300	150	
A /45 /2025	PM 2.5	Avg, ug/M 3	18	11	11	11	43	70	35	There were 0 exceedances of the Project Limit for the day. Will Rogers Dust 2 Exceeded the Action limit.
4/15/2025	PM 10	Avg, ug/M 3	37	15	17	12	48	300	150	
A /4 C /2025	PM 2.5	Avg, ug/M 3	10	12	8	7	37	70	35	There were 0 exceedances of the Project Limit for the day. Will Rogers Dust 2 exceeded the Action levelfor the day.
4/16/2025	PM 10	Avg, ug/M 3	25	17	12	8	41	300	150	
4/17/2025	PM 2.5	Avg, ug/M 3	6	6	4	4	9	70	35	There were 0 exceedances of the Project Limit for the day.
	PM 10	Avg, ug/M3	26	10	7	5	10	300	150	
4/18/2025	PM 2.5	Avg, ug/M3	7	9	8	8	14	70	35	There were 0 exceedances of the Actin Level or Project Limit for the day.
	PM 10	Avg, ug/M3	23	14	14	9	18	300	150	
4/19/2025	PM 2.5	Avg, ug/M3	12	10	7	10	18	70	35	There were 0 exceedances of the Actin Level or Project Limit for the day.
	PM 10	Avg, ug/M3	37	14	12	12	22	300	150	
4/20/2025	PM 2.5	Avg, ug/M3	6	9	8	14	17	70	35	There were 0 exceedances of the Action Level or Project Limit for the day. There were no operations on Sunday April 20, 2025, so
	PM 10	Avg, ug/M3	15	11	11	15	17	300	150	the data included in this report is only from the TDSRs which have dust monitors running 24 hours per day.
	PM 2.5	Avg, ug/M3	12	12	11	16	20	70	35	There were 0 exceedances of the Action Level or Project Limit for the day.
4/21/2025	PM 10	ug/M3	37	18	16	17	22	300	150	
4/22/2025	PM 2.5	Avg, ug/M3	15	14	13	17	19	70	35	There were 0 exceedances of the Action Level or Project Limit for the day.
	PM 10	Avg, ug/M3	40	18	17	18	22	300	150	
4/23/2025	PM 2.5	Avg, ug/M3	10	10	8	12	11	70	35	There were 0 exceedances of the Action Level or Project Limit for
-1 231 ZUZ3	PM 10	Avg, ug/M3	29	15	13	13	14	300	150	the day.
4/24/2025	PM 2.5	Avg, ug/M3	12	11	12	12	9	70	35	There were 0 exceedances of the Action Level or Project Limit for the day.
	PM 10	Avg, ug/M3	40	17	17	13	11	300	150	
4/25/2025	PM 2.5	Avg, ug/M3	7	8	9	8	6	70	35	There were 0 exceedances of the Action Level or Project Limit for the day.
	PM 10		25	12	15	9	9	300	150	
4/26/2025	PM 2.5	Avg, ug/M3	5	5	3	5	3	70	35	There were 0 exceedances of the Action Level or Project Limit for
	PM 10		18	8	6	6	5	300	150	the day.
4/27/2025	PM 2.5	Avg, ug/M3	8	6	2	4	2	70	35	There were 0 exceedances of the Action Level or Project Limit for the day.
	PM 10		29	9	5	4	3	300	150	

There were 0 exceedances of the Action Level or Project Limit for the day. There were 0 exceedances of the Action Level or Project Limit for the day.		300	10					ug/M3		
the day.	35		10	14	16	15	31		PM 10	
150	33	70	9	13	11	12	10	Avg, ug/M3		4/29/2025
There were 0 exceedances of the Action Level or Project Limit for	150	300	10	14	17	18	32		PM 10	
the day.	35	70	15	21	12	13	12	Avg, ug/M3		4/30/2025
150	150	300	16	22	16	19	33		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	18	12	12	13	20	Avg, ug/M3	PM	5/1/2025
150	150	300	15	18	38	20	13		PM 10	
There were 0 exceedances of the Action Level or Project Limit for	35	70	16	7	8	10	16	Avg, ug/M3		5/2/2025
the day.	150	300	21	8	11	14	31		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	13	10	8	10	17	Avg, ug/M3		5/3/2025
150	150	300	15	11	10	14	32	Avg, ug/M3	PM 10	
There were 0 exceedances of the Action Level or Project Limit for	35	70	12	7	11	11	14	Avg, ug/M3		
the day.	150	300	15	7	16	18	28		PM 10	5/4/2025
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	1	7	11	11	17	Avg, ug/M3		5/5/2025
150	150	300	1	8	17	19	33		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	0	5	9	10	13	Avg, ug/M3		5/6/2025
150	150	300	0	6	14	17	26		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	0	6	10	12	14	Avg, ug/M3		5/7/2025
150	150	300	0	7	17	20	33		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	6	0	13	13	16	Avg, ug/M3	PM 2.5	5/8/2025
150	150	300	7	0	21	22	43		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day. Will Rogers Dust 1 was offline today.	35	70		17	14	13	19	Avg, ug/M3		5/9/2025
150	150	300		17	18	18	47		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	25	16	14	14	23	Avg, ug/M3		5/10/2025
150	150	300	27	18	221	21	54		PM 10	
There were 0 exceedances of the Action Level or Project Limit for the day.	35	70	15	16	18	16	23	Avg, ug/M3		5/11/2025
150	150	300	15	17	26	24	57		PM 10	